



**Ancient Monuments and Archaeological Areas Act 1979  
Scheduled Monument Consent Decision Notice**

<b>Case ID</b>	<b>300018674</b>	<b>Index no</b>	<b>SM13099</b>
<b>Scheduled Monument</b>	<b>Linlithgow Palace, Peel and Royal Park</b>		
<b>Location/Address</b>	<b>West Lothian</b>		
<b>Proposed Works</b>	<b>Loch Wall Strengthening at Town Bay</b>		

Historic Environment Scotland hereby **grants** scheduled monument consent for the works detailed below without conditions.

**Consented Works:**

- a) The placing of a 75mm layer of crushed rock onto the loch bed
- b) Retaining wall base to consist of concrete filled geotextile bags (grade C40/10), placed before fully set
- c) Retaining wall concrete to be suitable for placing below water level, with shutter comprising of 250 x 130 railway sleepers with HD polythene inner face
- d) Retaining wall to be tied to existing revetment with stainless steel ties, drilled and anchored at 1000mm centres.
- e) Installation of new precast concrete edge coping

as described in your application which we validated on 04 November 2016 and the following supporting document:

- Loch Retailing Wall: Loch Wall Strengthening Ref: EDS4.1.57/09B

**Reasons for the Decision:**

The works proposed are considered acceptable in meeting the terms of national policy for scheduled monuments, and also accounting for other material considerations.

.....

28 December 2016

Historic Environment Scotland  
Longmore House  
Salisbury Place  
Edinburgh  
EH9 1SH

Tel: 0131 668 8716

Email: [ScheduledMonumentConsent@hes.scot](mailto:ScheduledMonumentConsent@hes.scot)